Multimortar

Firestop Mortar





Product Data Sheet



Multimortar

Firestop Mortar













Firestop Mortar

Composed of perlite and non-organic compounds, Multimortar is a dry white powder that when mixed with water creates a durable, thermally insulating and fire-resistant mass. When used to seal openings in walls or floors, it prevents the spread of fire and smoke through fire-resistant structures, while maintaining their acoustic properties.

Multimortar is part of the Mulcol® Penetration Seal System. The Multimortar can be used in combination with the Multicollar Slim, Multidisc, Multiwrap, Multitherm Bandage and Multimastic FB firestop boards.

Advantages

- Fire resistance ≤ 240 minutes
- CE-certified
- High acoustic insulation
- Easy to install
- Smooth finish
- Suitable for most surfaces

Hardened less than 1 hour

Technical data

Applications

- Rigid walls and floors
- Flexible walls
- Cable trays, cable ladders, electric cables and cable bundles
- Plastic pipes up to Ø 40 mm without fire collar
- Plastic pipes up to Ø 160 mm with fire collar or wrap
- Multilayer pipes with or without insulation
- Metal pipes up to Ø 324 mm with elastomeric or rock wool insulation
- Finishing around fire dampers
- Gas pipes, drinkpipes, electrical room services etc.
- Blank seals

Colour	Off-white		
Shelf life	Indefinetly if kept in an unopened bag in a dry place above +5 $^{\circ}\text{C}$		
Application temperature	0 °C to +40 °C		
Temperature resistance	resistance -20 °C to +70 °C		
Hardened	Less than 1 hour, depending on the local climate		
VOC content	<1g/L		
Reaction to fire	A1 in accordance with EN 13501-1		



Packaging

	Contents	Pallet	Pallet	Article number
Bag	15 kilos	60 bags	900 kilos	209001020

Usage (mixing ratio 2:1)

Approximately 3.42 bags per m² (with a thickness of 50 mm) Approximately 6.83 bags per m² (with a thickness of 100 mm)

Technical documents available

- ✓ Product Data Sheet (PDS)
- Technical Data Sheet (TDS)
- Safety Data Sheet (SDS)
- Installation Manual
- CE certificate
- Emission reports
- Acoustic report

Approvals

- Tested in accordance with EN 1366-3
- Classification in accordance with EN 13501-2
- Certified in accordance with EAD 350454-00-1104
- Tested in accordance with NEN 6075 (Smoke-resistance)
- ETA report 23/0057
- Declaration of Performance (DoP)

The above documents are available from your Mulcol contact or via www.mulcol.com















